



FIRE ALARM REQUIREMENTS PLACES OF ASSEMBLY

CITY OF LACONIA FIRE PREVENTION DIVISION
848 NORTH MAIN STREET, LACONIA, NH 03246
Call (603) 524-6881 for appointments and information

FIRE
PREVENTION
Fire Alarms

200-16

January 2017

Assembly – Special Amusement:

Smoke detection and/or connection to the Municipal System may be required.
Contact the fire prevention office for specific criteria.

Assembly – Over 300 Occupants:

Municipal System shall be required.

An approved automatic sprinkler system shall be required.

Assembly – Theaters:

In addition to the requirements for Municipally Connected fire alarms, a manual fire alarm box shall be installed on every stage, near any fixed lighting control panel and in any projection booth.

A combination rate of rise and one hundred thirty-five degrees (135°) temperature heat detector shall be installed above all stage areas, below all accessible stage areas and in every projection booth.

A manual fire alarm box shall be installed on every stage, near any fixed lighting control panel, and in every projection booth.

Manual fire alarm boxes, with the approval of the authority having jurisdiction, may be omitted from exits and installed in such supervised locations as the ticket booth or the refreshment stand.

Notification appliances shall be installed where required by the authority having jurisdiction. A complete fire alarm/voice communication system with an automatic voice evacuation message is required. The actuation of the fire alarm system shall automatically interrupt all theater audio systems and automatically raise the house lights.