



FIRE ALARM REQUIREMENTS EDUCATIONAL

CITY OF LACONIA FIRE PREVENTION DIVISION
848 NORTH MAIN STREET, LACONIA, NH 03246
Call (603) 524-6881 for appointments and information

FIRE
PREVENTION
Fire Alarms

200-17

January 2017

A total coverage fire alarm system as defined in NFPA 72 — *Initiating Devices, Detector Coverage* and a Municipally Connected System as prescribed shall be installed in all educational occupancies.

The fire alarm requirement shall not apply to educational occupancies meeting the following criteria:

- (1) The building does not have a gross area over 1,000 square feet
- (2) The building contains only one classroom
- (3) The building is located not less than 30 feet from another building

In **NEW** educational occupancies carbon Monoxide detection is required.

In cases where instruction is incidental to some other occupancy, the section of these regulations governing the other occupancy shall apply.

Sunday Schools or church schools that are not used for daily classes throughout the week shall comply with that section of this chapter dealing with **Places of Public Assembly and Day Care Centers.**

